

工程名称	金源高端设备股份有限公司2.97MW光伏电站					
测试地点	2号楼		测试时间			
仪器型号			测试人			
组串数量			天气情况			
逆变器编号	开路电压	对地电压	逆变器编号	开路电压	对地电压	备注
2号逆变器			5号逆变器			
1	754		1	758		
2	754		2	760		
3	755		3	767		
4	754		4	760		
5	751		5	752		
6	754		6	754		
7	754		7	752		
8	753		8	753		
9	754		9	753		
10	753		10	755		
11	750		11	759		
12			12	757		
3号逆变器			6号逆变器			
1	754		1	750		
2	754		2	747		
3	755		3	748		
4	755		4	753		
5	756		5	755		
6	757		6	754		
7	758		7	757		
8	758		8	745		
9	762		9	745		
10	758		10	749		
11	756		11			
12			12			
4号逆变器			7号逆变器			
1	757		1	747		
2	755		2	747		
3	755		3	745		
4	754		4	745		
5	756		5	746		
6	756		6	747		
7	760		7	753		
8	760		8	755		
9	759		9	753		
10	756		10	754		
11	757		11	753		
12			12	763		



工程名称	金源高端设备股份有限公司2.97MW光伏电站					
测试地点	3号楼		测试时间			
仪器型号			测试人			
组串数量			天气情况			
逆变器编号	开路电压	对地电压	逆变器编号	开路电压	对地电压	备注
6号逆变器	764		3号逆变器			
1	764		1	764		
2	765		2	764		
3	764		3	762		
4	764		4	767		
5	767		5	766		
6	767		6	760		
7	765		7	760		
8	762		8	759		
9	765		9	761		
10	768		10	762		
11	769		11	763		
12			12	764		
5号逆变器			2号逆变器			
1	768		1	761		
2	768		2	765		
3	769		3	763		
4	772		4	762		
5	771		5	760		
6	773		6	765		
7	771		7	768		
8	770		8	770		
9	766		9	778		
10	778		10	770		
11	768		11	772		
12	778		12			
4号逆变器			1号逆变器			
1	760		1	752		
2	758		2	758		
3	760		3	760		
4	759		4	754		
5	776		5	760		
6	763		6	756		
7	772		7	754		
8	768		8	750		
9	764		9	746		
10	768		10	749		
11	771		11	747		
12	765		12			

